

ठाणे महानगरपालिका

131



महानगरपालिका भवन, डॉ. अल्मोडा रोड, चंदनवाडी, पांचपाखाडी, ठाणे-४००६०२

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

प्रदूषण नियंत्रण कक्ष

POLLUTION CONTROL CELL

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O. 1168(E) dt.01.06.02



Ref./T.M.C./P.C.C./VTN - 27361

Sample No.: 983/1

Date: 09 February 2024

Water Analysis Report

Name Of the Organisation : New Horizon Scholars School, Rodas
Address: Kolshet, Thane
E-mail: nhssr.stores@newhorizonsms.org
Mobile No.: 7208021242
Date of receiving Sample: 30 January 2024
Sample Collected by: By Party
Type of Water Sample: Sewage Treatment Plant

Parameters	Results	Limits
pH	6.59	6.5-8.5
COD	25	50 mg/L
Suspended Solids	46	100 mg/L
BOD	7	10 mg/L
Oil & Grease	BDL(<1.0)	10 mg/L
MPN	0	230TC/100 ml
E-Coli	Absent	0/100 ml
F-Coli	Absent	0/100 ml

All results are in ppm except pH.

Remarks: The analyzed parameters are within limit.

This is the analysis report of the Sewage Treatment Plant sample received to our Vartak Nagar Laboratory on 30 January 2024. This further acknowledges that you have paid the charges Rs. 24720/- vide Receipt No. TMC/LOS/PLC/000267/23-24 (Jan 24 - Dec 24) dated 01 February 2024.

Analysed By

Akash Jagtap

Lab Attendant, PCC

Thane Municipal Corporation, Thane

Approved By

Vaishali S. Palkar

Deputy Environment Officer, PCC

Thane Municipal Corporation, Thane

Ms
Principal

New Horizon Scholars School
Hiranandani Estate, Thane.

Manager
New Horizon Scholars School
Hiranandani Estate, Thane